

Emission Test Certificate

Friday August 7th, 2009

Supplier: Trafalgar Fire Containment Solutions (8/52 Holker Street, Silverwater NSW 2128)

Sample Description: Fyreplug

Date Tested: August 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

| Fyreplug | Total Volatile Organic Compound Specific Area Emission Rate mg/m ² /hr |
|---|--|
| 24 hours | 0.05 |
| This product can be classed as low VOC-emitting. The material emissions are less than a recognised threshold of 0.5 mg/m ² /hr; e.g. “Green Star”. | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV090731